Inc. Standard 19 or Federal Specification ZZ-H-451E. Hose that bears the label of Underwriters' Laboratories, Inc. as lined firehose is accepted as conforming to this requirement.

[CGFR 65-50, 30 FR 17001, Dec. 30, 1965, as amended by CGD 74-60, 41 FR 43151, Sept. 30, 1976; CGD 76-086, 44 FR 2392, Jan. 11, 1979; CGD 88-032, 56 FR 35826, July 29, 1991; CGD 95-012, 60 FR 48051, Sept. 18, 1995; CGD 95-027, 61 FR 26007, May 23, 1996; CGD 95-028, 62 FR 51206, Sept. 30, 1997; USCG-2000-7790, 65 FR 58461, Sept. 29, 2000]

§95.10-15 Piping.

- (a) All piping, valves, and fittings shall meet the applicable requirements of subchapter F (Marine Engineering) of this chapter.
- (b) All distribution cut-off valves shall be marked as required by §97.37–10 of this subchapter.
- (c) For vessels on an international voyage, the diameter of the fire main shall be sufficient for the effective distribution of the maximum required discharge from two fire pumps operating simultaneously. This requirement is in addition to §95.10–5(c). The discharge of this quantity of water through hoses and nozzles at a sufficient number of adjacent hydrants shall be at a minimum Pitot tube pressure of approximately 50 pounds per square inch.

§ 95.10-90 Installations contracted for prior to May 26, 1965.

Installations contracted for prior to May 26, 1965, shall meet the following requirements:

(a) Except as specifically modified by this paragraph, the requirements of §§ 95.10-5 through 95.10-15 shall be complied with insofar as the number and general type of equipment is concerned. Existing equipment, except firehose nozzles and low-velocity water spray applicators, previously approved, but not meeting the applicable requirements of §§ 95.10-5 through 95.10-15 may be continued in service so long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs, alterations, and replacements may be permitted to the same standards as the original installations. However, all new installations or major replacements shall meet the applicable requirements in this subpart.

(b) All vessels contracted for prior to November 19, 1952, other than motorboats, shall be fitted with fire pumps, hoses, and nozzles in accordance with Table 95.10–90(a)(2).

TABLE 95.10-90(a)(2)

Gross tons		Min-	Min- imum		
Over	Not over	imum number of pumps	hose and hy- drant size, inches	Nozzle orifice size, inches	Length of hose feet
100 1,000	100 1,000	1 1 2	1 1½ 2 1½ 2 1½	1 5/ ₁₆ 2 5/ ₈ 2 5/ ₈	¹ 50 ² 50 ² 50

¹ On vessels of 65 feet in length or less, ³/₄-inch hose of good commercial grade together with a commercial garden hose nozzle may be used. The pump may be hand operated and the length of hose shall be sufficient to assure coverage of all parts of the vessel.

2 May use 50 feet of 21/₆ inch hose with 7/₆ inch page 11/₆ inch

² May use 50 feet of 2½-inch hose with ⁷/₈-inch nozzles for exterior stations. 75 feet of 1½-inch hose with ⁵/₈-inch nozzles may be used for interior station in which case such interior stations shall have siamese connections.

- (c) Vessels contracted for prior to July 1, 1935, need not meet the requirements of §95.10–5(h), and vessels contracted for on or after July 1, 1935, but prior to November 19, 1952, may have a carbon dioxide "bilge" in lieu of "total flooding" system. However, in vessels of both categories where a conversion from coal to oil is contracted for on or after November 19, 1952, the provisions of §95.10–5(h) shall apply.
- (d) The general requirements of §95.10–5(c) through (g), §95.10–10(d) through (i), and §95.10–15 shall be complied with insofar as is reasonable and practicable.
- (e) Firehose nozzles and low-velocity spray applicators must meet the requirements of 95.10–10(i), 95.10–10(j), and 95.10–10(k).

[CGFR 65-50, 30 FR 17001, Dec. 30, 1965, as amended by CGD 76-086, 44 FR 2392, Jan. 11, 1979; CGD 95-027, 61 FR 26007, May 23, 1996]

Subpart 95.13—Steam Smothering Systems

§ 95.13–1 Application.

Steam smothering systems are not permitted on vessels contracted for on or after January 1, 1962. Previously approved installations may be retained as long as they are maintained in good